

**FC24 - <offline>**

"LAMP\_TEST"


**Name:**  
**Author:** Cristian  
**Time stamp Code:**  
**Lengths (block/logic/data):** 00198 00102 00000

**Family:**  
**Version:** 0.1  
**Block version:** 2  
05/07/2008 10:58:44 AM  
02/08/1999 12:15:15 PM

Name	Data Type	Address	Comment
IN		0.0	
OUT		0.0	
IN_OUT		0.0	
TEMP		0.0	
RETURN		0.0	
RET_VAL		0.0	

**Block: FC24**


Network: 1



**Symbol information**

M151.1	ZERO MODE MCP
I3.0	Button Lamp Test MCP
Q4.0	Remote Mode MCP Light
Q4.1	Local Mode MCP Light
Q4.2	Auto Pumps MCP Light
Q4.3	Local Pumps MCP Light
Q4.4	Start Button MCP Light
Q4.5	Press.Alarm MCP Light
Q4.6	Warning MCP Light
Q4.7	Alarm Reset MCP Light
Q5.0	SCP Enabled Light
Q5.1	P#1 Start B. MCP Light
Q5.2	P#2 Start B. MCP Light
Q5.3	P#3 Start B. MCP Light
Q5.4	P#4 Start B. MCP Light
Q5.5	C#1 Start B. MCP Light
Q5.6	C#2 Start B. MCP Light
Q9.4	Delivery warning L.


Network: 2



**Symbol information**

I7.4	Button Lamp Test SCP
M97.2	SCP_BIT
Q6.0	Warning SCP Light
Q6.1	Alarm Reset SCP Light
Q6.2	Aux.Drives Enable Light
Q6.3	Brakes Press.High Light
Q6.4	Left S. Pin UP SCP Light
Q6.5	Left S.Pin Dow.SCP Light
Q6.6	Left S.Pin P-in SCP L.
Q6.7	Left S.Pin P-out SCP L.
Q7.0	Right S.Pin UP SCP Light
Q7.1	Right S.Pin Dow.SCP Lig.
Q7.2	Right S.Pin P-in SCP L.
Q7.3	Right S.Pin P-out SCP L.
Q5.7	SCP Enabled

Network: 3



**Symbol information**

M151.1	ZERO MODE MCP
Q4.0	Remote Mode MCP Light
Q4.1	Local Mode MCP Light
Q4.2	Auto Pumps MCP Light
Q4.3	Local Pumps MCP Light
Q4.4	Start Button MCP Light
Q4.5	Press.Alarm MCP Light
Q4.6	Warning MCP Light
Q4.7	Alarm Reset MCP Light
Q5.0	SCP Enabled Light
Q5.1	P#1 Start B. MCP Light
Q5.2	P#2 Start B. MCP Light
Q5.3	P#3 Start B. MCP Light
Q5.4	P#4 Start B. MCP Light
Q5.5	C#1 Start B. MCP Light
Q5.6	C#2 Start B. MCP Light
Q9.4	Delivery warning L.