

OB1 - <offline>

""

Name: **Family:**
Author: **Version:** 0.1
Block version: 2
Time stamp Code: 04/26/2007 03:45:02 PM
Interface: 07/06/1998 09:41:25 AM
Lengths (block/logic/data): 00248 00124 00020

Name	Data Type	Address	Comment
TEMP		0.0	
TEMP0	Byte	0.0	
TEMP1	Byte	1.0	
TEMP2	Byte	2.0	
TEMP3	Byte	3.0	
TEMP4	Byte	4.0	
TEMP5	Byte	5.0	
TEMP6	Int	6.0	
TEMP7	Int	8.0	
TEMP8	Int	10.0	
TEMP9	Date_And_Time	12.0	

Block: OB1**Network: 1**

```

L      27648
T      MW      84
L      27980
T      MW      202
UC     "Analog Inputs to TCS"      FC19
UC     "STARTING VALUES"          FC27
UC     "Convers. values PLC-TCS"   FC12
  
```

Network: 2

```

UC     "ALARM quantity's program"  FC10
UC     "ALARMS DB11quantity"       FC14
UC     "Warn quantity's program"   FC11
UC     "WARNING DB12 quantity"     FC15
UC     "ALARMS OP7's program"      FC13
UC     "WARNINGS OP7's program"    FC16
  
```

Network: 3

```

UC     "Search ranges T°"          FC17
UC     "Estimate Qa , Qak"        FC18
  
```

Network: 4

```

UC     "ALARMS_PLC"               FC21
UC     "WARNINGS_PLC"             FC25
UC     "MAIN_MCP"                 FC22
UC     "MAIN_SCP"                 FC30
UC     "POWER_PROGRAM"            FC26
UC     "LAMP_TEST"                FC24
  
```

Network: 5

UC "Digital I/O to TCS" FC20

Network: 6

BE